

Board of Health Minutes

July 17, 2006

The meeting opened at 6:25 p.m. with Ms. Day, Ms. Meehan, and Ms. Ryan present. Ms. Perrault and Ms. Devanney were absent.

Tyngs Crossing - Dave Trahan/Dennis Page Subdivision – Off Farwell Road

Mr. Hannaford represented the builders in requesting variances for the septic systems for Lots A,B,C on Farwell Road and Lots 1,3,5 Jonathon Way.

The variances included:

3.2 G – Depth of parent material below the bottom of the leaching area in soils with a percolation rate of two minutes per inch or less, and lot is not serviced by municipal water – 6 feet required – All the lots will have 6 feet of material, but not parent material. All lots average at least 4 feet of parent material with a 2 min/inch perk rate.

The Board approved the variance request for all the above lots.

Other Business:

Ms. Ferrari again encouraged the Board to go on line to take the ICS 100 course. That course is a prerequisite for NIMS 700 and 200.

The meeting adjourned at 7:10 P.M.